

2021 AUG 26 AM 10:51



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

Punkin W/A #1 & Punkin W/A #2 Deer Run
Public Water System Name

MS0360013 & MS0360031
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)

DATE ISSUED

☒ Advertisement in local paper (Attach copy of advertisement)

8/22/21 & 8/29/21

☐ On water bills (Attach copy of bill)

☐ Email message (Email the message to the address below)

☐ Other _____

DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)

DATE ISSUED

☐ Distributed via U. S. Postal Mail

☐ Distributed via E-Mail as a URL (Provide Direct URL): _____

☐ Distributed via E-Mail as an attachment

☐ Distributed via E-Mail as text within the body of email message

☐ Published in local newspaper (attach copy of published CCR or proof of publication)

☐ Posted in public places (attach list of locations)

☒ Posted online at the following address (Provide Direct URL): www.punkinwaterassoc.com

CERTIFICATION

"2020 Annual Drinking Water Quality Report"

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

[Signature]
Name

Bookkeeper
Title

8/23/21
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

(NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2021 AUG 11 AM 7:41

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#: 0360013		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								

10. Barium	N	2020	.0282	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	1.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.121	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	50000	32000 - 50000	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Disinfection By-Products

81. HAA5	N	2020	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2020	1.2	1 – 1.3	Mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

PWS ID#: 0360031

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2019*	.0091	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019*	.124	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019*	57000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.

Volatile Organic Contaminants

76. Xylenes	N	2020	.0069	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	-------	----------	-----	----	----	---

Disinfection By-Products

81. HAA5	N	2017*	15	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	19.8	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.1	.7 – 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2020.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Punkin Water Association works around the clock to provide top quality water to every tap. We request our customers help us to protect our water sources, which are the heart of our community, our way of life and our children's future.

Proof

Client	PUNKIN WATER ASSOCIATION	Phone	(662) 234-4331
Address	PO BOX 114	EMail	deeannahill1@gmail.com
	OXFORD, MS 38655	Fax	
AD #	1296132	Requested By	PUNKIN WATER ASSOCIATION
Class	2610	PO #	
Start Date	08/22/21	Created By	
End Date	08/29/21	Creation Date	BRITTANY.SCH
Run Dates	4	Dimensions	08/18/2021
Pubs	Oxford Eagle, OxfordEagle.com	Price	4 X 16.85
Order #	1296132		\$1,688.00
Sales Rep	Brittany Schofield	Phone	
		EMail	brittany.schofield@shelbycountyreporter.com
		Fax	

August 202

If you have any questions about this report or concerning your water utility, please contact Jason Butts at 662-816-1871 or 662-832-5546. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday each month at 6:00 PM at the Lafayette County Courthouse Building, Supervisor's Meeting Room, 100 North Lamar Blvd., Oxford, MS 38655.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we provided the following definitions:

- Acceptable Use:** Utilization of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must fulfill.
- Maximum Contaminant Level Goal (MCLG):** The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLGs are set without regard to treatment technology.
- Maximum Contaminant Level (MCL):** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected adverse health effects.
- Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contamination.
- Maximum Residual Disinfectant Level Goal (MRDLG):** The goal of a drinking water disinfectant below which there is no known or expected adverse health effects. (Do not revert the merits of the use of disinfectants to control microbial contamination.)
- Permit:** A written agreement between a water system and the state that sets forth the conditions of operation for a water system for a period of two years or a weight basis of \$10,000. Permits per year at Morgan Hill for one permit per billion gallons of use monthly to one million in 2,225,000, or a single permit is \$10,000.

^a That recent sample. No sample required for 2019.

* All recent samples. No sample included the 2016

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDM now notifies systems of any missing samples prior to the end of the compliance period.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. Their health should remain under close medical supervision. EPA's guidelines on appropriate means to reduce the risk of infection by cryptosporidium and other microorganisms are available from the U.S. Environmental Protection Agency at www.epa.gov/safewater.

The Puget Water Association works around the clock to provide top quality water to every day. We request our customers help us to protect our water sources, which are the heart of our community, our way of life and our children's future.